



3030 Hospital Dr. NW Calgary, AB T2N 4W4  
8440-112 St. Edmonton, AB T6G 2J2

403-944-1215  
780-407-8925



**9670250, Hardisty**

Box 10

Hardisty AB  
T0B1V0  
(780)888-3623

**Sedgewick Environmental Public Health**

4822 - 50 Street  
Sedgewick, AB T0B 4C0

Accession #: WE-17-0040752  
AESRD Approval #: 0000759  
EI/ProvLab Study #:

**Environmental Microbiology**

Collected Date 2017-04-25  
Collected Time 11:10 MDT

		Units
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL

Drinking Water Sample Category	Treated Public
Received Date and Time	2017-04-26 0700
Analyzed Date	2017-04-26
ID Number	660962
Sample Collected By	Ivan Lesmeister
Collected By Phone Number	780-888-1363
Sample Collection Site.	See Below

2017-04-25 11:10 MDT Sample Collection Site.  
Post Office bathroom sink

2017-04-25 11:10 MDT Total Coliforms by Enzyme Substrate:  
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

**LEGEND:**

@=Faxed

\*=Footnotes

#=Corrected

H=High

Cc:

**Information on this report relates only to this sample**  
**For further information contact the Environmental Public Health Agency**

Chart Request ID: 150224356  
Print Date/Time: 2017-04-27 14:56

Env: ER4 - Provider - Permanent  
Page 1 of 1