



3030 Hospital Dr. NW Calgary, AB T2N 4W4
8440-112 St. Edmonton, AB T6G 2J2

403-944-1215
780-407-8925



9621283, Hardisty

Box 10

Hardisty AB
T0B1V0

Sedgewick Environmental Public Health

4822 - 50 Street
Sedgewick AB T0B 4C0

Accession #: WE-17-0046110
AESRD Approval #:
EI/ProvLab Study #:

Environmental Microbiology

Collected Date	2017-05-08	
Collected Time	11:25 MDT	
		Units
Total Coliforms by Enzyme Substrate *	PRESENT @*	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL

Drinking Water Sample Category	Untr. Public	
Received Date and Time	2017-05-09 0700	
Analyzed Date	2017-05-09	
ID Number	660967	
Sample Collected By	Ivan Mesmeister	
Collected By Phone Number	780-888-1363	
Sample Collection Site.	See Below	

2017-05-08 11:25 MDT Sample Collection Site.
Warden Office kitchen tap

2017-05-08 11:25 MDT Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

2017-05-08 11:25 MDT Total Coliforms by Enzyme Substrate:
*If repeat samples are submitted, please check one box under the category "Resample - Drinking Water (previous sample showed presence of Coliforms)"

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency

Chart Request ID: 150919074
Print Date/Time: 2017-05-10 10:20

EXPEDITED CHART
Page 1 of 1