



3030 Hospital Dr. NW Calgary, AB T2N 4W4
8440-112 St. Edmonton, AB T6G 2J2

403-944-1215
780-407-8925



9670250, Hardisty

Box 10

Hardisty AB
T0B1V0
(780)888-3623

Sedgewick Environmental Public Health

4822 - 50 Street
Sedgewick AB T0B 4C0

Accession #: WE-16-0140871
AESRD Approval #: 0000759
EI/ProvLab Study #:

Environmental Microbiology

Collected Date 2016-12-13
Collected Time 10:40 MST

Total Coliforms by Enzyme Substrate *	ABSENT	Units
E coli by Enzyme Substrate	ABSENT	per 100mL
		per 100mL

Drinking Water Sample Category	Treated Public
Received Date and Time	2016-12-14 0909
Analyzed Date	2016-12-14
ID Number	660921
Sample Collected By	Terry Z
Collected By Phone Number	780-888-7404
Sample Collection Site.	See Below

2016-12-13 10:40 MST Sample Collection Site.
WTP - Sample point at new instalation or 6" Mag Meter

2016-12-13 10:40 MST Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

LEGEND: @=Faxed *=Footnotes #=Corrected H=High

Cc:

**Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency**

Chart Request ID: 143160278
Print Date/Time: 2016-12-15 14:29

EXPEDITED CHART
Page 1 of 1