



3030 Hospital Dr. NW Calgary, AB T2N 4W4
8440-112 St. Edmonton, AB T6G 2J2

403-944-1215
780-407-8925



9670250, Hardisty

Box 10

Hardisty AB
T0B1V0
(780)888-3623

Sedgewick Environmental Public Health

4822 - 50 Street
Sedgewick, AB T0B 4C0

Accession #: WE-17-0008660
AESRD Approval #: 0000759
EI/ProvLab Study #:

Environmental Microbiology

Collected Date 2017-01-24
Collected Time 10:55 MST

		Units
Total Coliforms by Enzyme Substrate *	ABSENT	per 100mL
E coli by Enzyme Substrate	ABSENT	per 100mL

Drinking Water Sample Category	Treated Public
Received Date and Time	2017-01-25 0907
Analyzed Date	2017-01-25
ID Number	660933
Sample Collected By	Terry Zapf
Collected By Phone Number	780-888-7404
Sample Collection Site.	See Below

2017-01-24 10:55 MST Sample Collection Site.
Dream Creations bathroom sink

2017-01-24 10:55 MST Total Coliforms by Enzyme Substrate:
Total Coliforms and E coli testing performed by Enzyme Substrate Method - Presence/Absence.

LEGEND: @=Faxed * =Footnotes # =Corrected H=High

Cc:

Information on this report relates only to this sample
For further information contact the Environmental Public Health Agency

Chart Request ID: 145298203
Print Date/Time: 2017-01-26 15:01

Env: ER4 - Provider - Permanent
Page 1 of 1